



NOTES:

1. THIS DRAWING IS FOR DEVELOPMENT AND PLANNING PURPOSES.

2. SUGGESTED MINIMUM BENDING RADII

630mm <sup>2</sup> SINGLE CORE COPPER XLPE	580mm
630mm <sup>2</sup> SINGLE CORE ALUMINIUM XLPE	580mm
800mm <sup>2</sup> SINGLE CORE COPPER XLPE	660mm
800mm <sup>2</sup> SINGLE CORE ALUMINIUM XLPE	660mm
1000mm <sup>2</sup> SINGLE CORE COPPER XLPE	710mm
1000mm <sup>2</sup> SINGLE CORE ALUMINIUM XLPE	710mm

REFERENCES:

ENA 12-24 ISSUE 2 TECHNICAL SPECIFICATION FOR CABLE DUCTING

ENA 97-1 EXTRACT TECHNICAL SPECIFICATION FOR CBS BACKFILL

ENA 12-23 TECHNICAL SPECIFICATION FOR TILE TAPE & TILE BOARD COVERS

NJUG GUIDELINES FOR CABLE SEGREGATION



Enso Energy Limited, Unit 1 & 2 Cirencester Office Park,  
Tetbury Road, Cirencester, GL7 6JJ  
Tel: 01452 764685 Email: enquiries@ensoenergy.co.uk

Revisions:  
First Issue- 13/06/2023 JS



ALL DIMENSIONS TO BE CHECKED ON SITE WORK TO FIGURED DIMENSIONS ONLY REPORT DISCREPANCIES TO THE GFP AT ONCE BEFORE PROCEEDING COPYRIGHT ACT APPLIES.

© Enso Energy Ltd. Crown Copyright. All rights reserved.  
© 2023 Emapsite license number 0100031673

Project Title:  
**Alaw Môn (Wylfa) Solar Farm**

Drawing Title:  
**132kV Connection Cable Arrangement Between the NG Substation and the Solar Substation**

DRWG No: WAM-01-P19	Rev: -	Sht no: -
Drawn by : JS	Checked by: OH	
Scale: 1:20 @ A2	Date: 13/06/2023	